



ABN: 56 130 495 493

18 Stacer Street Upper Coomera QLD 4209

Mob: 0410 657 399

email: [peter@slipsmart.com.au](mailto:peter@slipsmart.com.au)



Accredited for compliance with  
ISO/IEC 17025 - Testing  
Laboratory No. 15041

This report has been prepared for: *MJS Floorcoverings Pty. Ltd.*

35 Dividend Street , Mansfield QLD 4122

**Test Site: Laboratory Tests Tru Plank –Winter Fog**

**Report Number: W1089**

**Date Tested: 07/09/2021**

**Australian Standard Applied: AS4586:2013**

**Nature and Purpose Of Tests:**

**The Nature of the Wet slip tests is as per AS4586:2013 Appendix A**

**The purpose of the Wet slip test is to ascertain an SRV for the surfaces requested.**

## WET Slip Resistance Test Report for Pedestrian Surfaces

This report has been prepared for: **MJS Floorcoverings Pty. Ltd. – Kerry Krebs,**  
35 Dividend Street , Mansfield QLD 4122

**Test Site: Laboratory Tests Tru Plank – Winter Fog 2mm/0.30 x 184 x 1219mm\***

Standard Applied:	AS 4586-2013	<b>Notes:</b>						
Rubber Type:	Slider 96	1. The areas tested below were carried out <b>on site</b> using the Wessex Pendulum friction tester ID: SK1271, conditioned with grade P400 paper followed by wet 3 micron lapping film, to evaluate the frictional characteristics of the pedestrian surface.						
Fixed or unfixed surface:	Unfixed	2. SlipSmart Pty Ltd assumes no responsibility or civil liability for any actions whatsoever that may arise as a result of the tests and the publication and issue of this test report.						
Cleaning type:	Nil	3. Slip test results always remain the property of SlipSmart Pty Ltd. This test report is intended for viewing solely for the named recipient identified above.						
Topography:	Lab	4. This report contains privileged and confidential information. The unauthorised reproduction of this report is prohibited.						
Accelerated wear (if appropriate):	n/a	Environmental Conditions:	Fine, Dry	Date tested:	07/09/2021			
Slope:	n/a	Temperature:	24°C	Job Number:	W1089			
<i>Sample Tested</i>		Air Temp. °C	Floor Type	Coating	British Pendulum Number	Slip Resistance Value	Slope Correction Value	Equivalent AS4586-2013 Classification
Test area #1		24	2mm/0.30x184x1219mm vinyl	Nil	25	<b>24</b>	<b>00</b>	<b>P1</b>
Test area #2		24	2mm/0.30x184x1219mm vinyl	Nil	24			
Test area #3		24	2mm/0.30x184x1219mm vinyl	Nil	23			
Test area #4		24	2mm/0.30x184x1219mm vinyl	Nil	23			
Test area #5		24	2mm/0.30x184x1219mm vinyl	Nil	23			

Other observations:

Remarks: \*Sample details supplied by Client

Signatory   
Brent Vournechis

Peter Vournechis

Tested By: B Vournechis

