

# VOC Content Test Certificate

Wednesday August 18<sup>th</sup>, 2010

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137)

Sample Description: InterfaceFlor Seam Sealer

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p style="text-align: center;"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b></p>	<p style="text-align: center;"><b>InterfaceFlor Seam Sealer</b></p>
<p>Indoor Carpet Adhesive 50 grams per Litre as VOC content material</p>	<p><b>&lt;1 grams per Litre as VOC content per material</b></p>
<p style="text-align: center;"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b></p>	<p style="text-align: center;"><b>InterfaceFlor Seam Sealer</b></p>
<p>Indoor Carpet Adhesive 50 grams per Litre as VOC content material</p>	<p><b>&lt;1 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F1008-11**