AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Tarkett Australia Pty Ltd

Suite 1 Level 3 3 Columbia Court

Baulkam Hills NSW 2153

Sample Description Clients Ref : "Somplan 350"

Homogeneous Compact Vinyl Floorcovering

Nominal Composition: Vinyl

Nominal Mass per Unit Area/Density: 3300g/m2

Nominal Thickness: 2mm

AS 4586-2013 Appendix A Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 12/05/2020

Test Temperature (20±5degC) 22 °C

Sample Preparation Washed with pH neutral detergent and dried

Test Direction Length

Fixed/Unfixed Unfixed

Slider No 96 Batch No 87

 Length
 1
 2
 3
 4
 5
 SRV

 British Pendulum
 38
 38
 38
 37
 37
 38

Number

Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019 Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

203079 43891 Page 1 of 1

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing

- Mechanical Testing

- Performance & Approvals Testing

: Accreditation No. : Accreditation No.

: Accreditation No. 985 : Accreditation No. 1356

983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

MICHAEL A. JACKSON B.Sc.(Hons)

20-002125

13/05/2020

13/05/2020

Test Number :

Issue Date

Print Date

APPROVED SIGNATORY