


Environmental Certification Scheme

Carpet Name: TRUE DIMENSIONS 16 OZ



Licensee: INTERFACE
Licence Number: 1016
Label Number: 22166

Certification Approved:

Level: 4

ACCS Contract Grading: CEHD 4*
ACCS Residential Grading: NONE
Suitable for Stairs: Yes

Date Printed: 25/03/2022

Allan Firth



Allan Firth
Secretary ACCS



Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303
PO Box 7172, St Kilda Road, Melbourne Victoria 8004 Tel: (03) 9804 5559 • Fax: (03) 9804 5560
Email: info@carpetoz.com.au • www.carpetinstitute.com.au

This certificate remains the property of the Carpet Institute of Australia Limited.

Carpet Details:**Company: INTERFACE****Label No: 22166****Licence No: 1016****Office No: 7242****Names:**

TRUE DIMENSIONS 16 OZ

Details:

Awarded Res Grade: NONE
 Awarded Con Grade: CEHD 4*
 Registered On: 18/02/2022
 Active: Yes
 Date In-Active:
 Manufacture Method: Tufted
 Twist Set: N/A
 Dyeing Method: Melt Dyed
 #Colours/Designs: 4/1
 Backing Type: Other
 Felted: N/A
 Spinning System: BCF
 Insect Resist Agent: N/A
 Filament: 21.3
 Master Product:

Test Results:

Pile Mass g/m² (oz/yd²): 543 (16.0)
 SPM g/m² (oz/yd²): 361.7 (10.7)
 Stated Pile Height (mm): 2.6
 Minimum Pile Height (mm): 0.0
 Maximum Pile Height (mm): 0.0
 Dynamic Loading Loss (%): 0.0
 Static Loading Loss (%): 0.0
 Tex (g/1000m): 300
 Measured Pile Thickness (mm): 2.6
 Machine Gauge (Tufts/dm): 41.0
 Meas Tufts Perp to Selvedge: 41.0
 Meas Tufts Para to Selvedge: 38.0
 Treated For Soiling Resistance: Yes
 Soil Resist Inhibitor: Yes
 Stain Resist Inhibitor: Yes

Hexapod Scores:

	Texture		Colour		Thickness	
	WA		WA		(mm)	(%)
1500:	4.0	0.0	4.0	0.0	0.2	6.7
8000:	3.0	0.0	3.0	0.0	0.6	20.0

Quality Assurance Test:

Cut Pile (%): 0
 Loop Pile (%): 100
 Panel Assessment Contract: 14
 Panel Assessment Residential: 14
 Suitable For Stairs: Yes
 Tile: Yes SheetGoods: No
 Fibre Signature: NBA:100

ACCS Test:

	Con	Res	Max
SPM/PH Ratio:	12.6	16	16
Volume Density:	12.5	12.5	20
Tuft Density:	7.8	7.8	9
Dyn Load:	3.9	3.9	5
Stat Load:	4.1	4.1	5
Soiling Prop:	14	14	16
Abrasion Res:	9.2	9.2	10
Sub Total:	64.1	67.5	81
Panel Assess:	14	14	19
Total:	78.1	81.5	100
Calc Residential Grade:	REHD2		6*
Calc Contract Grade:	CHD		3*

Calculations

Pile Height(mm): 3.9
 Tuft Density(per dm²): 1558.0
 GSPM(g/m²): 410.0
 GSPM (abrasive) (g/m²): 275.0
 Soiling Propensity: 12.0 +2.0

OAF Values

OAF: 4.2
 Calc Density (+-5%): 0.13 0.139 0.15
 Base Fibre: NYLON
 Benchmarks:
 RHD1 0 RHD2 3.5
 REHD1 3.5 REHD2 3.5

Environmental Classification:

ECS: Yes
 Level: 4

	Calc	B/M	P/F
Acoustic:	2.6	3	
Thermal:	18.7	15	PASS
VOC:			
TVOC	120		

Notes:

18/2/2022 Submitted by X Traslavina. 23/2/2022 Needs Extractable Matter and Pill Test results. Panel awarded an INTERIM grading of CEHD(S) 4* and ECS Level 4. 25/3/22 Compliant Extractable Matter & Pill Test provided. Grading of CEHD(S) 4* and ECS Level 4 confirmed. Original submission name CUSTOM MJS 16 OZ removed.