

VOC Content Test Certificate

Wednesday 2nd February 2022

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: Max Bond TRP Temperature Resistant Plank Adhesive

Date Tested: August 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Max Bond TRP Temperature Resistant Plank Adhesive</p>
<p>General Purpose adhesives and sealants: 50 grams per Litre</p>	<p align="center">1 gram per Litre as VOC content per material</p>
<p align="center"><i>We hereby certify that Max Bond TRP Temperature Resistant Plank Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V2112046 Ver1